

DATA SHEET

battery fuse protection

enwitec-Article-No.	10015453
Customer-Article-No.	
Matchcode	Bat Breaker-BYD_LVLPR-9xAcc-3xCharg_KS
Application	Battery fuse "Bat Breaker – BYD Premium LVL" for the PV energy storage system with battery charger / inverter
Number and type of battery charger / inverter:	Max. 3 Sunny Island
Number and type of energy storage:	Max. 9x BYD Premium LVL
General note:	If a different battery charger / inverter is to be used, the suitability of the circuit breaker used (nominal value, tripping characteristic) must be checked by BYD Cable lugs are not included


Min. Distances:

Up and down min. :
300 mm

Left and right min. :
200 mm

After Front min.:
800 mm

Cable clamping:
Must be done on site!



Delivery			
designation	Article-No.	Piece	comments
Pflitsch cable gland M32x1,5	10011807	24	
Locknut M32x1,5	10000724	24	
Twisting Sleeve M32 x 1.5	10008835	4	

