

# CE marking : EC declaration of conformity



Range: **iEM3000**

Products: **See Annexes**

We undersigned **SCHNEIDER-ELECTRIC INDUSTRIE SAS** declare that the products mentioned in Annex 1 comply <sup>(1) (2)</sup> with the following:

- Electromagnetic Compatibility Directive 2004/108/EC**
- Low voltage Directive 2006/95/EC**

Additionally, products mentioned in Annex 2 comply <sup>(1) (2)</sup> also with the following:

- Measuring instruments Directive 2004/22/EC**  
EC-type examination certificates n° 0120/ SGS0098 & 0120/ SGS0099

<sup>(1)</sup> when subject to correct installation, maintenance and use conforming to their intended purpose, according to applicable regulations and standards in the country where they are installed, to the supplier's instructions and to accepted rules of the art

<sup>(2)</sup> The CE marking on the product(s) and/or its(their) packaging signifies that Schneider Electric holds the reference technical file(s) available to the European authorities

**Stephen McKee** - Vice President, Customer Satisfaction and Quality

Date: 27/05/2014

Signature:

## Annex 1 (EMCD, LVD)

Commercial name(s)	Commercial reference(s)	CE marking application date	Applicable standards
iEM3100 iEM3150 iEM3200 iEM3250	A9MEM3100 A9MEM3150 A9MEM3200 A9MEM3250	2012 (updated)	<b>As Power Meter / Power Monitor:</b> <ul style="list-style-type: none"> <li>■ EN 61557-12:2008</li> <li>■ EN 61326-1:2013</li> <li>■ EN 61010-1:2010</li> <li>■ EN 61010-2-030:2010</li> </ul>
iEM3300 iEM3350	A9MEM3300 A9MEM3350	2014	<b>As Sub-Meter:</b> <ul style="list-style-type: none"> <li>■ EN 62052-11:2003</li> <li>■ EN 62053-21:2003 / EN 62053-22:2003</li> </ul>

## Annex 2 (EMCD, LVD & MID)

Commercial name(s)	Commercial reference(s)	CE marking application date	Applicable standards
iEM3110 iEM3115 iEM3210 iEM3215	A9MEM3110 A9MEM3115 A9MEM3210 A9MEM3215	2012 (updated)	<b>As Power Meter / Power Monitor:</b> <ul style="list-style-type: none"> <li>■ EN 61557-12:2008</li> <li>■ EN 61326-1:2013</li> <li>■ EN 61010-1:2010</li> <li>■ EN 61010-2-030:2010</li> </ul>
iEM3310	A9MEM3310	2014	<b>As Sub-Meter:</b> <ul style="list-style-type: none"> <li>■ EN 62052-11:2003</li> <li>■ EN 62053-21:2003 / EN 62053-22:2003</li> </ul> <b>As MID Sub-Meter:</b> <ul style="list-style-type: none"> <li>■ EN 50470-1:2006</li> <li>■ EN 50470-3:2006</li> </ul>
iEM3135 iEM3155 iEM3165 iEM3175 iEM3235 iEM3255 iEM3265 iEM3275	A9MEM3135 A9MEM3155 A9MEM3165 A9MEM3175 A9MEM3235 A9MEM3255 A9MEM3265 A9MEM3275	2012 (updated)	<b>As Power Meter / Power Monitor:</b> <ul style="list-style-type: none"> <li>■ EN 61557-12:2008</li> <li>■ EN 61326-1:2013</li> <li>■ EN 61010-1:2010</li> <li>■ EN 61010-2-030:2010</li> </ul>
iEM3335 iEM3355 iEM3365 iEM3375	A9MEM3335 A9MEM3355 A9MEM3365 A9MEM3375	2014	<b>As Sub-Meter:</b> <ul style="list-style-type: none"> <li>■ EN 62052-11:2003</li> <li>■ EN 62053-21:2003 / EN 62053-22:2003</li> <li>■ EN 62053-23:2003</li> </ul> <b>As MID Sub-Meter:</b> <ul style="list-style-type: none"> <li>■ EN 50470-1:2006</li> <li>■ EN 50470-3:2006</li> </ul>